



October 6, 2010

DALMARAY CONCRETE PRODUCTS, INC
AARON AUSEN
405 S ARCH ST
JANESVILLE WI 53548

Re: Description: **SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS]**
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC
Product Name: **SEPTIC/BIO-MICROBICS FAST 0.5, 0.75, 0.9; AND SEPTIC/BIO-MICROBICS HIGH STRENGTH FAST 1.0**
Model Number(s): 750/1250
[TANK DIMENSIONS = 146 IN. L X 78 IN. W X 55 IN. H; MAX. DEPTH OF BURY 108 IN.]
[SEE MAX. DWF AND INFLUENT CHARACTERISTICS FOR EACH PRE-TREATMENT UNIT]
Product File No: 20100368

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- This system must have an adequately sized septic tank for the design upstream of this unit.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV